

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0026:219 Page 1 of 1

CATEGORY: Photoelectric Smoke Detectors

LISTEE: Simplex, *100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Model 4098-9601, 4098-9602 and 4098-9605 photoelectric type smoke detectors. Model 4098-9602 employs an integral 135°F heat sensor. This heat sensor is intended for use as a supplemental device to the smoke detector. Refer to listee's data sheet for additional detailed system description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as photoelectric type smoke detectors for use with separately listed compatible fire alarm control units. Intended for use with listee's separately listed Models 4098-9682, -9683 or -9788 detector base. For indoor use only.

*Rev. 06-21-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager